

Clearlake Oaks County Water District
PO Box 709 / 12952 E. Hwy 20
Clearlake Oaks, CA 95423
Phone 707-998-3322, Fax 707-998-1247

Customer Shut-Off Valve & Pressure Regulator Policy

In addition to District Ordinance 31, all water service connections are required to have the following facilities:

- 1) a customer shut-off valve installed within two feet of the meter box, on the customer side of the meter, and
- 2) a pressure regulating device installed on the customer side of the meter box.

All costs associated with the installation, maintenance, or repair of the above referenced facilities shall be the sole burden of the customer.

As approved by the Board of Directors, of the Clearlake Oaks County Water District on the 24th day of May, 2002.